
ATTENZIONE CAMBIO DI GESTIONE PIN 8 E 10

AVVERTENZA DA APPLICARE AI PRODOTTI:

8D5897 _ 2G Lift Dialer
8D5896 _ 4G Lift Dialer
8D5897B _ 2G Lift Dialer Box
8D5896B _ 4G Lift Dialer Box

IN CASO DI SOSTITUZIONE DEGLI APPARATI.





Nel corso dello sviluppo del progetto 2G/4G Dialer è stata **modificata la gestione dei PIN** sulla morsettiera.
In particolare il **PIN 10 da Positivo (+) è stato definito come Massa (GND)**.

In caso di sostituzione di apparati è importante verificare che la gestione del PIN 10 sul Dialer sia compatibile con il cablaggio dell'impianto.

PIN	DESCRIZIONE
1	LINEA TELEFONICA su 2G DIALER // NON USATO su 4G DIALER
2	LINEA TELEFONICA su 2G DIALER // NON USATO su 4G DIALER
3	TELEFONO
4	TELEFONO
5	VOICE BOX
6	VOICE BOX
7	IN F (FILTRO ALLARME)
8	**IN SOS**
9	IN T (ALLARME TECNICO)
10	**GND (IN F , IN SOS , IN T)**

DIGICOM è un marchio di B810 S.p.A.
ITALY • Viale Luigi Cadorna 95 20025 Legnano – MI • Tel. +39 0331 702611

B810 S.p.A.
ITALY • Via Lazzaretti 2/1 Z.I. Mancasale 42122 Reggio Emilia • Tel. +39 0522 510200 • Fax +39 0522 506299
www.b810group.it


ATTENTION CHANGE OF HANDLING PIN 8 AND 10

WARNING TO BE APPLIED TO PRODUCTS:

8D5897 _ 2G Lift Dialer **8D5897B _ 2G Lift Dialer Box**
8D5896 _ 4G Lift Dialer **8D5896B _ 4G Lift Dialer Box**

IN CASE OF EQUIPMENT REPLACEMENT.





During the development of the 2G/4G Dialer project, the **PIN management on the terminal box was modified**.
In particular, **PIN 10 was defined as Ground (GND) from Positive (+)**.

In the event of equipment replacement, it is important to verify that PIN 10 management on the Dialer is compatible with the system wiring.

PIN	DESCRIPTION
1	TELEPHONE LINE on 2G DIALER // NOT USED on 4G DIALER
2	TELEPHONE LINE on 2G DIALER // NOT USED on 4G DIALER
3	PHONE
4	PHONE
5	VOICE BOX
6	VOICE BOX
7	IN F (ALARM FILTER)
8	**IN SOS**
9	IN T (TECHNICAL ALARM)
10	**GND (IN F , IN SOS , IN T)**

DIGICOM is a trademark of B810 S.p.A.
ITALY • Viale Luigi Cadorna 95 20025 Legnano – MI • Tel. +39 0331 702611

B810 S.p.A.
ITALY • Via Lazzaretti 2/1 Z.I. Mancasale 42122 Reggio Emilia • Tel. +39 0522 510200 • Fax +39 0522 506299
www.b810group.it